



NOTES:

1. CARE SHALL BE TAKEN WHEN INSTALLING VALVES TO ASSURE PROPER SUPPORT OF THE VALVE. THE DISTRICT MAY REQUIRE THE 3/4" CRUSHED ROCK TO BE INSTALLED UNDER THE VALVE TO PROVIDE PROPER SUPPORT.
2. VALVES SHALL NOT BE PLACED IN CONCRETE CROSS PANS.
3. OPERATING NUTS SHALL NOT BE SET CLOSER THAN THREE (3) FEET TO FINAL GRADE OR DEEPER THEN FIVE (5) FEET FROM FINAL GRADE. OPERATOR EXTENSIONS SHALL BE CONNECTED TO VALVE OPERATOR USING SET SCREW.
4. GATE VALVE SHALL BE POLYETHYLENE WRAPPED.

GATE VALVE